

UNITED

LABORATORIES

United 524

CONTROLS:

Growth of slime forming bacteria which is the major cause of drain blockages. Clean condensate drain and pan.

DO NOT REMOVE UNIT HOUSING PRECAUTIONARY STATEMENTS

CORROSIVE. Causes irreversible eye damage and skin burns. Do not get in eyes, on skin, or clothing. Wear chemical goggles, protective clothing, and rubber gloves. May be fatal if swallowed, absorbed through the skin, or inhaled. Wash thoroughly with soap and water after handling and before eating, drinking, chewing gum, or smoking tobacco. Remove contaminated clothing and wash before reuse.

ENVIRONMENTAL HAZARDS: This product is toxic to fish.

FIRST AID:	
If in eyes:	<ul style="list-style-type: none"> Hold eye open and rinse slowly and gently with water for 15-20 minutes. Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye. Call a poison control center or doctor for treatment advice.
If on skin:	<ul style="list-style-type: none"> Take off all contaminated clothing. Rinse skin immediately with plenty of water for 15-20 minutes. Call a poison control center or doctor for treatment advice.
If swallowed:	<ul style="list-style-type: none"> Call a poison control center or doctor immediately for treatment advice. Have person sip a glass of water if able to swallow. Do not induce vomiting unless told to do so by the poison control center or a doctor. Do not give anything by mouth to an unconscious person.
If inhaled:	<ul style="list-style-type: none"> Move person to fresh air. If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably mouth-to-mouth if possible. Call a poison control center or doctor for further treatment advice.
<p>Have the product container or label with you when calling a poison control center or doctor, or going for treatment. For emergency information on product, usage etc., call 1-800-636-7363, Monday through Friday 9 a.m. to 4:30 p.m. EST. After 4:30 p.m. call your poison control center.</p>	

NOTE TO PHYSICIANS:

Probable mucosal damage may contraindicate the use of gastric lavage.

ANTI-OVERFLOW CARTRIDGE

Preventative Maintenance For
Air Conditioning Condensate
Drain Systems
For Industrial Use Only

— **DO NOT REMOVE UNIT HOUSING.** —
KEEP OUT OF REACH OF CHILDREN.
DANGER

See other precautions on the left side panel
of this container and on the use directions
enclosed.

ACTIVE INGREDIENTS:

Alkyl (60% C14, 30% C16, 5% C12, 5% C18)
dimethyl benzyl ammonium chloride..... 20%
Alkyl (68% C12, 32% C14) dimethyl
ethyl benzyl ammonium chloride 20%
INERT INGREDIENT:..... 60%
TOTAL: 100.0%

Sold By:
UNITED LABORATORIES, INC.
320 37th Avenue • St. Charles, IL 60174
1-800-323-2594 • www.unitedlabsinc.com

DIRECTIONS FOR USE:

It is a violation of Federal law to use this product in a manner inconsistent with its labeling.

- DO NOT USE IN:** HUMIDIFIERS, HUMIDIFIER SECTIONS OF AIR CONDITIONING SYSTEMS OR EVAPORATIVE COOLERS.
- Clean condensate pan and drain before installing unit.
- Place unit in pan, pad side down.
- In pans with drain connections, place unit under the cooling coil in the middle of pan length.
- Unit must be in contact with condensate.
- This unit is designed and approved only for use in drain pans of Air Conditioning Systems and Refrigeration Systems.

STORAGE AND DISPOSAL:

STORAGE AND DISPOSAL: Store in a dry place no lower in temperature than 50°F. or higher than 120°F. Avoid heat, sunlight, friction, contaminating substances, especially anionics, shock and crushing. Do not reuse empty carton or plastic housing. Discard cartons and plastic housing in trash.

EPA REG. NO. 33427-4-9250
EPA EST. NO. 33427-NY-01

NOT INTENDED FOR CONSUMER HOUSEHOLD USE.

Printed in U.S.A.

805

NET CONTENTS: