

UNITED



LABORATORIES

Ideal for treating lift stations, grease traps and mains, **BIO-ACCEL** stimulates the biodegradation of grease and other organic waste with two-way action.

First, the core of **BIO-ACCEL** is released as a slug dose into the waste stream within minutes. It consists of a critical blend of enzymes designed to accelerate the breakdown of wastes and stimulate biological activity.

Secondly, the outer block of **BIO-ACCEL** is also comprised of a critical blend of enzymes, containing 10,000 IU/gram. It is designed to release these enzymes slowly, providing 60 - 180 days of continuous grease and odor control.

- Easy installation with minimal ongoing attention.
- Eliminates odors.
- Earth Smart[®] Certified.
- Near neutral pH.
- Ideal for lift stations and grease traps.
- Works at temperature range 38°F to 165°F, with optimum temperature ranges 65°F to 110°F.
- Excellent for grease, scum and oil removal.
- Safe for plant and process...will enhance bacterial process in plant.
- No hazardous components, no VOCs, ranked zero in all HMIS numbers.
- Non-toxic according to EPA, OSHA, NIOSH and WHMIS standards.
- Presents no material safety handling or closed space issues.

HMIS® CODE: 0=MINIMAL 1=SLIGHT 2=MODERATE 3=SERIOUS 4=SEVERE PERSONAL PROTECTION INDEX: Glasses and Gloves	HEALTH	0
	FLAMMABILITY	0
	REACTIVITY	0
	PERSONAL PROTECTION	В

United 856

BIO-ACCEL

for Grease and
Odor Control in
Wastewater Environments
with Inter-Core Technology
Patent Pending

KEEP OUT OF REACH OF CHILDREN. CAUTION

SEE SIDE PANEL FOR ADDITIONAL PRECAUTIONARY STATEMENTS.

PRECAUCION AL USARIO:

Si usted no puede leer Ingles, pregunte a alguien que le traduzca esta etiqueta para usted antes de uso.

Sold Exclusively By:
UNITED LABORATORIES, INC.
320 37th Avenue • St. Charles, IL 60174
1-800-323-2594 • www.unitedlabsinc.com

DIRECTIONS:

Grease Traps: BIO-ACCEL should be suspended in the trap so the block is just under the grease cap. Apply one 2 lb. block for every 350 gallons capacity. If capacity is over 350 gallons, spread the blocks out in different sections of the trap.

Manholes and Mains: In manhole, BIO-ACCEL should be placed in the U channel nearly vertically pointed downstream on the upstream end of the U channel.

Lift Stations: BIO-ACCEL should be used in low flow applications. Suspend the block so the entire block is submerged below the water at its lowest level

Lift Station Flow	Block Size	Number of Blocks
Under 50,000 gal.	2 lb.	1
50,000-100,000 gal.	2 lb.	2

EMERGENCY AND FIRST AID PROCEDURES:

EYES: Flush with plenty of water for at least 15 minutes while keeping the eyelids wide open. If irritation persists, seek medical attention.

SKIN: Wash with soap and water. Launder clothing. If irritation or redness persists, seek medical attention.

INHALATION: Not applicable.

INGESTION: Thoroughly rinse mouth with water. Drink one or two glasses of water. Slight gastrointestinal discomfort may occur.

An MSDS for this product is available through United's website, www.unitedlabsinc.com, providing 24 hour access. Please read the MSDS carefully and follow all directions when using or handling this product. Never reuse empty containers. Incompatible materials may adversely react.